

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0113964

Owner: Mid-American Coaches, Inc.
Address: P.O. Box 1609, Washington, MO 63090

Continuing Authority: Same as above
Address: Same as above

Facility Name: Mid-American Coaches
Facility Address: 4530 Highway 47 South, Washington, MO 63090

Legal Description: SW ¼, SW ¼, SW ¼, Sec. 35, T44N, R1W, Franklin County
Latitude/Longitude: +3831028/-09100156

Receiving Stream: Unnamed Tributary to Busch Creek (U)
First Classified Stream and ID: Tributary to Busch Creek (C)(01687)
USGS Basin & Sub-watershed No.: (10300200-130001)


is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 - Bus Facility (wash, maintenance, dump station) - SIC #5541
Oil-water separator/extended aeration/sludge holding tank/sludge disposal is by contract hauler.
Design population equivalent is 77.
Design flow is 2,660 gallons per day.
Design sludge production is 1.38 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

July 23, 2004
Effective Date


Stephen M. Mahford, Director, Department of Natural Resources
Executive Secretary, Clean Water Commission

July 22, 2009
Expiration Date
MO 780-0041 (10-93)

Jim Hull, Director of Staff, Clean Water Commission

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

PERMIT NUMBER MO-0113964

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

Outfall Number and Effluent Parameter(S)	Units	Final Effluent Limitations			Monitoring Requirements	
		Daily Maximum	Weekly Average	Monthly Average	Measurement Frequency	Sample Type
Outfall #001 Flow	MGD	*		*	once/month	24 hr. estimate
Biochemical Oxygen Demand ₅	mg/L	45		30	once/quarter**	grab
Chemical Oxygen Demand	mg/L	30		20	once/quarter**	grab
Total Suspended Solids	mg/L	45		30	once/quarter**	grab
Fecal Coliform	#/100mL	1000		400	once/quarter**	grab
Chloride	mg/L	250		250	once/quarter**	grab
Phosphorus, Total	mg/L	0.5		0.5	once/quarter**	grab
Oil & Grease	mg/L	15		10	once/quarter**	grab
Sodium	mg/L	250		250	once/quarter**	grab
Lead, Total Recoverable	µg/L	12.0		12.0	once/quarter**	grab
Boron, Total Recoverable	µg/L	2,000		2,000	once/quarter**	grab
Zinc, Total Recoverable	mg/L	1.623		1.483	once/quarter**	grab
Copper, Total Recoverable	µg/L	64		41	once/quarter**	grab
Nickel	mg/L	5.4		0.6	once/quarter**	grab
Aluminum	mg/L	0.75		0.75	once/quarter**	grab
Mercury	µg/L	2		2	once/quarter**	grab
Manganese	mg/L	*		*	once/quarter**	grab
Cadmium	µg/L	68		16.4	once/quarter**	grab
Iron	mg/L	1		1	once/quarter**	grab
Chromium	µg/L	280		190	once/quarter**	grab
Residual Chlorine	µg/L	***		***	once/quarter**	grab
Temperature	°F	90		90	once/quarter**	grab
pH - Units	SU	****		****	once/quarter**	grab
Surfactants	mg/L	*		*	once/quarter**	grab

MONITORING REPORTS SHALL BE SUBMITTED QUARTERLY; THE FIRST REPORT IS DUE October 28, 2004. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

B. STANDARD CONDITIONS

IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED Parts I & III
STANDARD CONDITIONS DATED October 1, 1980 and August 15, 1994, AND HEREBY INCORPORATED AS
THOUGH FULLY SET FORTH HEREIN.

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- * Monitoring requirement only.
- ** Sample once per quarter in the months of February, May, August, and October.
- *** Residual Chlorine shall not be present in detectable amounts.
- **** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.
4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
 - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
5. Report as no-discharge when a discharge does not occur during the report period.

C. SPECIAL CONDITIONS (continued)

6. General Criteria. The following water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
- (a) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (b) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (c) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (d) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (e) There shall be no significant human health hazard from incidental contact with the water;
 - (f) There shall be no acute toxicity to livestock or wildlife watering;
 - (g) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (h) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.
7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
- (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
 - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids that are removed from the domestic wastewater treatment lagoon during lagoon clean-out and maintenance activities. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids from the lagoon. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.

D. SCHEDULE OF COMPLIANCE

The permittee shall upgrade the treatment facility to meet the effluent limits for fecal coliform set by the Clean Water Commission with the following schedule:

- 1. By November 30, 2004, submit an engineering report identifying the steps to improve the existing treatment facility or eliminate the discharge.
- 2. By March 31, 2005, submit plans and specifications and an application form with the appropriate fee for a construction permit to improve the existing facility or eliminate discharge.
- 3. By May 31, 2006, this project shall be completed in accordance with the approved plans and specifications. This facility shall meet the fecal coliform limitations listed in Part A of this permit.